

December 28, 2009

QUALITY CULVERT INC
CARL TYNER
25726 COUNTY ROAD 561
PO BOX 435
ASTATULA FL 34705

Re: Description: FITTINGS, POLYETHYLENE
Manufacturer: QUALITY CULVERT INC
Product Name: STORM SEAL (10.8 psi) FABRICATED FITTINGS
Model Number(s): ELBOWS(22-1/2, 45, 90): 8, 10, 12, 15, 18, 24, 30, 36, 42, 48; END PLUGS (BELLED OR SPIGOT): 8, 10, 12, 15, 18, 24, 30, 36, 42, 48; REDUCER: 8x4, 8x6, 10x4, 10x6, 10x8, 12x4, 12x6, 12x8, 12x10, 15x4, 15x6, 15x8, 15x10, 15x12, 18x4, 18x6, 18x8, 18x10, 18x12, 18x15, 24x4, 24x6, 24x8, 24x10, 24x12, 24x15, 24x18, 30x4, 30x6, 30x8, 30x10, 30x12, 30x15, 30x18, 30x24, 36x4, 36x6, 36x8, 36x10, 36x12, 36x15, 36x18, 36x24, 36x30, 42x4, 42x6, 42x8, 42x10, 42x12, 42x15, 42x18, 42x24, 42x30, 32x36, 48x4, 48x6, 48x8, 48x10, 48x12, 48x15, 48x18, 48x24, 48x30, 48x36, 48x42; TEES and WYES: 8x4, 8x6, 8x8, 10x4, 10x6, 10x8, 10x10, 12x4, 12x6, 12x8, 12x10, 12x12, 15x4, 15x6, 15x8, 15x10, 15x12, 15x15, 18x4, 18x6, 18x8, 18x10, 18x12, 18x15, 18x18, 24x4, 24x6, 24x8, 24x10, 24x12, 24x15, 24x18, 24x24, 30x4, 30x6, 30x8, 30x10, 30x12, 30x15, 30x18, 30x24, 30x30, 36x4, 36x6, 36x8, 36x10, 36x12, 36x15, 36x18, 36x24, 36x30, 36x36, 42x4, 42x6, 42x8, 42x10, 42x12, 42x15, 42x18, 42x24, 42x30, 42x36, 42x42, 48x4, 48x6, 48x8, 48x10, 48x12, 48x15, 48x18, 48x24, 48x30, 48x36, 48x42, 48x48 (All dimensions are in inches) Options: 4" and 6" would be HDPE Series 1000 SDR 26 - ASTM F714-03, 8" is HDPE Series 1000 SDR 26 - ASTM F714-03, 10" to 24" is HDPE Series 1000 SDR 32.5 - ASTM F714-03)
Product File No: 20090427

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) and (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following drain or vent use(s):
 - a. Sanitary sewer gravity flow
 - b. Storm sewer gravity flow
- This product must be labeled with size and product description (tee, wye, ell, etc.) in permanent yellow lettering and numbers painted on the exterior surface of the fitting.

QUALITY CULVERT INC.
Page 2
December 28, 2009
20090427

This approval supersedes the approval issued on March 19, 2004 under product file number 20040112.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040112.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov